

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1134-CPR-005

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the products Construction Products Regulation or CPR), this certificate applies to the construction product

Heat detector Aritech DT713-5R

with the variants and the performances listed in annex of this certificate and for the intended use:
Fire safety

manufactured by or for

Carrier Fire & Security BV
Kelvinstraat 7
6003 DH Weert
Nederland

and produced in the manufacturing plants

Carrier Safety System (Hebei) Co. Ltd.
N°.80 Changjiang East Road
QETDZ
066004 Qinhuangdao
Hebei
China

This certificate attests that all provisions concerning the assessment and the verification of constancy performance and the performances described in Annex ZA of the standard(s):

EN 54-5:2000/A1:2002

under system 1 are applied and that

the products fulfil all prescribed requirements set out above.

This certificate was first issued on 2013-09-11 and remains valid as a long time as the testing methods and/or for the control of the production in factory included in the harmonized standard, used to evaluate the performances of the declared characteristics, do not change and as neither the product, nor the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Brussels, 18 juin 2021



Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be

Annex 1 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-005

Variants of the Aritech DT713-5R

Heat detector

Variants: DT713-5
DT713-7

Base with short-circuit isolator

Aritech DB702

Variants: DB702U

Brussels, 18 juin 2021



Marie Majerus
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.
cert@anpi.be - www.anpi.be

Annex 2 to the CERTIFICATE CONSTANCY OF PERFORMANCE

1134-CPR-005

Harmonised technical specification		EN 54-5:2000/A1:2002
Essential Characteristics	Performance Clause	
Nominal activation conditions / Sensitivity / Response delay (response time) and Performance under fire conditions		-
- Classification: DT713-5	A2	-
DT713-5R	A2	- 4.2
DT713-7	B	
- Position of heat sensitive element	pass	- 4.3
- Directional dependence	pass	- 5.2
- Static response temperature	pass	- 5.3
- Response times from typical application temperature	pass	- 5.4
- Response times from 25 °C	NA	- 5.5
- Response times from high ambient temperature	pass	- 5.6
- Reproducibility	pass	- 5.8
- Additional test for suffix S detectors	pass	- 6.1
- Additional test for suffix R detectors	pass	- 6.2
Operational reliability		
- Individual alarm indication	pass	4.4
- Connection of ancillary devices	pass	4.5
- Monitoring of detachable detectors	pass	4.6
- Manufacturer's adjustments	pass	4.7
- On-site adjustment of response behaviour	NA	4.8
- Marking	pass	4.9
- Data	pass	4.10
- Additional requirements for software-controlled detectors	pass	4.11
Tolerance to supply voltage		
- Variation in supply parameters	pass	5.7
Durability of operational reliability and response delay, temperature resistance		
- Cold (operational)	pass	5.9
- Dry heat (endurance)	NA	5.10
Durability of operational reliability, vibration resistance		
- Shock (operational)	pass	5.14
- Impact (operational)	pass	5.15
- Vibration, sinusoidal (operational)	pass	5.16
- Vibration, sinusoidal (endurance)	pass	5.17
Durability of operational reliability, humidity resistance		
- Damp heat, cyclic (operational)	pass	5.11
- Damp heat, steady state (endurance)	pass	5.12
Durability of operational reliability, corrosion resistance		
- Sulphur dioxide (SO ₂) corrosion (endurance)	pass	5.13
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity (operational)	pass	5.18
Note: NPD theoretically possible; except for durability of characteristics with declared performance NA (not applicable) for components to which the requirement does not apply		

Brussels, 18 juin 2021

Marie-Matthijs
Certification Manager

This certificate and the annexes may only be copied completely and without any alteration.

cert@anpi.be - www.anpi.be