



Notified Body No. 0370

# CERTIFICATE

No.

0370-CPR-3605

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### FIRE DETECTION AND FIRE ALARM SYSTEMS:

- CONTROL AND INDICATING EQUIPMENT
- POWER SUPPLY EQUIPMENT

MODEL: ZP1-F2, ZP1-F2-SC

Place on the market under the name of:

## CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7  
6003 DH WEERT (NETHERLANDS)

And produced in the manufacturing plant:

## CARRIER MANUFACTURING POLAND SPÓŁKA Z O. O.

UL. KOLEJOWA, 24, 39-100 ROPCZYCE (POLAND)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1: 2006; EN 54-4: 1997, EN 54-4: 1997/AC:1999, EN 54-4: 1997/A1:2002, EN 54-4:1997/A2:2006**

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 31<sup>st</sup> October 2019 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 28<sup>th</sup> June 2021.

**The monitoring assessment will be done before 31<sup>st</sup> July 2022**

Bellaterra, 28<sup>th</sup> June 2021



*p.a.*  
  
Applus<sup>+</sup>  
LGAI Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*This document is not valid without its technical annex; whose number coincides with that of the certificate.*

*You can check the validity of this certificate on our website: [www.appluslaboratories.com/certified\\_products](http://www.appluslaboratories.com/certified_products)*

## 0370-CPR-3605

Annexes according to **EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1996/A1:2006**

### FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 2: CONTROL AND INDICATING EQUIPMENT

| ESSENTIAL CHARACTERISTICS                                                               | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|-----------------------------------------------------------------------------------------|-----------------------------------|--------------------------------|
| General requirements                                                                    | 4.                                | PASS                           |
| General requirements for indications                                                    | 5.                                | PASS                           |
| The quiescent condition                                                                 | 6.                                | PASS                           |
| The fire alarm condition                                                                | 7.                                | PASS                           |
| Output to fire alarm devices (option with requirements)                                 | 7.8                               | PASS                           |
| Delays to outputs (option with requirements)                                            | 7.11                              | PASS                           |
| Fault warning condition (see also annex F)                                              | 8.                                | PASS                           |
| Total loss of the power supply (option with requirements)                               | 8.4                               | PASS                           |
| Disabled condition                                                                      | 9.                                | PASS                           |
| Disabling of addressable points (option with requirements)                              | 9.5                               | NA                             |
| Test condition (option with requirements)                                               | 10.                               | PASS                           |
| Standardized input/output interface (option with requirements –see also annex G)        | 11.                               | NA                             |
| Design requirements                                                                     | 12.                               | PASS                           |
| Additional design requirements for software controlled control and indicating equipment | 13.                               | PASS                           |
| Marking                                                                                 | 14.                               | PASS                           |
| Cold (operational)                                                                      | 15.4                              | PASS                           |
| Damp heat, steady state (operational)                                                   | 15.5                              | PASS                           |
| Impact (operational)                                                                    | 15.6                              | PASS                           |
| Vibration, sinusoidal (operational)                                                     | 15.7                              | PASS                           |
| Electromagnetic Compatibility (EMC)                                                     | 15.8                              | PASS                           |
| Supply voltage variation (operational)                                                  | 15.13                             | PASS                           |
| Damp heat, steady state (endurance)                                                     | 15.14                             | PASS                           |
| Vibration, sinusoidal (endurance)                                                       | 15.15                             | PASS                           |

PASS; NPD = No Performance Determined, NA = Not Apply

## 0370-CPR-3605

Annexes according to **EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**

### **FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 4: POWER SUPPLY EQUIPMENT**

| ESSENTIAL CHARACTERISTICS              | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|----------------------------------------|-----------------------------------|--------------------------------|
| General requirements                   | 4.                                | PASS                           |
| Functions                              | 5.                                | PASS                           |
| Materials, design and manufacture      | 6.                                | PASS                           |
| Documentation                          | 7.                                | PASS                           |
| Marking                                | 8.                                | PASS                           |
| Cold (operational)                     | 9.5                               | PASS                           |
| Damp Heat, steady state (operational)  | 9.6                               | PASS                           |
| Impact (operational)                   | 9.7                               | PASS                           |
| Vibration, sinusoidal (operational)    | 9.8                               | PASS                           |
| Electrostatic discharges (operational) | 9.9                               | PASS                           |
| Damp heat, steady state (endurance)    | 9.14                              | PASS                           |
| Vibration, sinusoidal (endurance)      | 9.15                              | PASS                           |

PASS; NPD = No Performance Determined, NA = Not Apply

Incorporating the following units:

1X-F2-MB Main control board  
 2010-1-RB Optional relay board  
 2010-1-SB Optional expander I/O board  
 2010-1-NB Optional Network board  
 2010-PS-20 2A Power Supply  
 2010-SK Scandinavian Key Lock and Key (Applicable to SC variant)

Available with the following languages kits:

-01 Dutch (NL) The Netherlands -02 French (FR) France - 03 English (UK) United Kingdom and Ireland -04 German (DE) Germany -05 Norwegian Norway -06 Swedish Sweden -07 Danish (DK) Denmark -08 English (AU) Australia -09 Spanish Spain -10 Italian Italy -11 Dutch (BE) Belgium -12 Irish Ireland -13 German (AT) Austria -14 Greek Greece -15 Arabic Middle East -17 English (US) United States of America -18 Polish Poland -19 Turkish Turkey -20 Czech Czech Republic -21 Portuguese Portugal -22 Hungarian Hungary -23 Danish (IS) Iceland -24 Slovakian Slovak Republic -25 Russian Russia -27 Lithuanian Lithuania -28 Finnish Finland -29 German (CH) Switzerland -30 Estonian Estonia -31 Latvian Latvia -32 French (BE) Belgium -33 French (CH) Switzerland -34 Italian (CH) Switzerland -36 French (Int) International French -40 Bulgarian Bulgaria -41 Belarusian Belarus -43 Ukrainian Ukraine -44 Serbian Serbia -45 Romanian (RO) Romania -46 German (Int) International German -48 Croatian Croatia -49 Macedonian Macedonia -50 Slovenian Slovenia -51 Hebrew Israel -71 Catalan Catalonia (Spain) -80 Chinese China -99 English (Int) International English.