

# EU Declaration of Conformity

# Texecom



Document Reference : DEC-K00212  
Notified Body : BRE Global

Bradwood Court, St. Crispins Way  
Haslingden, Lancashire, BB4 4PW  
United Kingdom

0832

Certificate No. 0832-CPR-F0012

Object of the declaration:  
Klaxon Fire Alarm Device

Part No.	Head Type	Description	TYPE
ESB-0002	FAC350WC	C-3-15 Conventional Beacon White SB	Type A IP21C
ESB-0004	FAC355WC	C-3-15 Conventional Beacon White DB (Edwards UTC)	Type B IP65


Hereby, Texecom declares that this equipment is in compliance with the essential requirements and other relevant provisions of the Directives.

305/2011/EU	Construction Products Regulation
2014/30/EU	EMC Directive
2011/65/EU	ROHS Directive

This is demonstrated by conformity against the following harmonised standards

Standard	Edition/ Date of Issue	Title of Standard
EN60529	1991/A1:2000	Degrees of protection provided by enclosures (IP code)
EN 61000-6-3	2007:A1:2011/AC:2012	Electromagnetic compatibility (EMC) — Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments
EN 55022	2010	Information technology - Radio disturbance characteristics - Limits and methods of measurement
EN 50130-4	2011	Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
EN54-23	2010	Information technology - Radio disturbance characteristics - Limits and methods of measurement

This declaration is issued under the sole responsibility of the manufacturer.

 Digitally signed by Hugh Devereux  
DN: cn=Hugh Devereux,  
o=Texecom, ou,  
email=hdevereux@texe.com, c=GB  
Date: 2016.05.12 12:17:07 +01'00'

Hugh Devereux  
Head of Approval & Compliance

**RELEASED**



CERTIFICATE NUMBER: FM35285