

Certificate of constancy of performance,

0832-CPR-F1705

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011
(the Construction Products Regulation or CPR), this certificate applies to the construction product

MCP2A-Rxxxxx-yyyy-zz Indoor Surface/Flush Mounting Conventional Call Point
(For full product details and conditions of use refer to appendix)

Produced by or for

KAC Alarm Company Limited

KAC House
Thornhill Road
North Moons Moat
Redditch
Worcestershire
B98 9ND
United Kingdom

and produced in the manufacturing plant(s)

KAC Alarm Company Limited

KAC House
Thornhill Road
North Moons Moat
Redditch
Worcestershire
B98 9ND
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance
and the performances described in Annex ZA of the standard(s)

EN 54-11:2001 + A1:2005 - Manual call points

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 17 January 2017 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 17 January 2017
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1705

Accessories:

SR	Surface Mounting Plastic Box
SR1T	Surface Mounting Plastic Box C/W 1 Terminal
SR2T	Surface Mounting Plastic Box C/W 2 Terminals
SR3T	Surface Mounting Plastic Box C/W 3 Terminals
SR4T	Surface Mounting Plastic Box C/W 4 Terminals
MR	Surface Mounting Metal Box
ETT	European Terminal Tray ETT1, 2 & 3
L	Earth Continuity Link
BZR/1	Bezel Type 1
BZR/2	Bezel Type 2
BZR/3	Bezel Type 3
M141W	Spacer Piece
PTR	Patress PTR, PTRE, PTR2T, PTR2TE, PTR3T & PTR3TE
C	Hinged Cover

Variants:

MCP2A-Rxxxxx-yyyy-zzISC

C = Hinged cover fitted

IS = intrinsically safe variant with hinge cover

Blank character(s) if not applicable

Notes:

Key to variable characters:

1. **XXXxx** = The series resistor value. 039xx (lowest 39 Ω), 4K7xx (highest 4.7 k Ω)
2. **xxxXx** indicates mounting (S=Surface mounted, F=Flush mounted)
3. **xxxxG** = Glass element, **xxxxF** = Flexible element
4. **yyyy** = Customer account code (Range: A000 to Z999 or STCK for standard stocked product).
5. **zz** (Range: 0-99) indicates customers marking options detailed on KAC controlled drawing 08/2639



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 17 January 2017
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.