

**Schneider Electric Buildings AB
DECLARATION OF PERFORMANCE
No. DP23029**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

1. Unique identification code of the product-type:
FFS06741030 Esmi Impresia Base Base Sounder

2. Intended use/es:
Fire detection and fire alarm systems

3. Manufacturer:
**Schneider Electric Buildings AB,
Mobilvägen 8, 22362 Lund, Sweden**

4. Authorised representative:
Not applicable

5. System/s of AVCP:
System 1

6. Harmonised standard(s):
**EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006
EN 54-17:2005, EN 54-17:2005/AC:2007**

Notified body:

**EVPU (Notified Body 1293)
1293-CPR-0893**

7. Declared performance/s:

Essential characteristics	Harmonized technical specification		Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1=N/A to C.5.3=N/A	cl. 5.2	Pass
Operational reliability	cl. 4.4 to 4.6, 5.4, C4=N/A	cl. 4	Pass
Durability of operational reliability: Temperature resistance	cl. 5.5, 5.6=N/A, 5.7 to 5.9	cl. 5.4, 5.5	Pass
Durability of operational reliability: Humidity resistance	cl. 5.8, 5.9, 5.10=N/A	cl. 5.6, 5.7	Pass
Durability of operational reliability: Shock and vibration resistance	cl. 5.12 to 5.15	cl. 5.9 to 5.12	Pass
Durability of operational reliability: Corrosion resistance	cl. 5.11	cl. 5.8	Pass

Durability of operational reliability: Electrical stability	cl. 5.16	cl. 5.3, 5.13	Pass
Durability of operational reliability: Resistance to ingress	cl. 5.17	---	Pass

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of manufacturer by:

Espoo 2024-03-26



Jan Ellonen

Offer Manager

(v1)