

Essentia Intelligent Switch Monitor EME210-I

Instruction Sheet
R10121GB3



Schneider Electric

www.se.com/buildings

R10121GB3
October 2023

© 2020-2023 – Schneider Electric. All Rights Reserved. This information is only to be used as guidance. Subject to changes and errors.

Contents

| | |
|---|----------|
| Safety Information | 4 |
| Related Information | 4 |
| 1 Essentia Intelligent Switch Monitor EME210-I..... | 4 |
| 1.1 Status indications | 4 |
| 1.2 Dimensions | 5 |
| 1.3 Essentia Intelligent Switch Monitor standard resistive monitoring mode connectivity diagram ... | 5 |

Safety Information

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction, installation, and operation of electrical equipment and has received safety training to recognize and avoid the hazards involved.

Related Information

For technical specifications, please refer to the Product Datasheet for FFS06720311 on se.com.


1 Essentia Intelligent Switch Monitor EME210-I

The Essentia switch monitor EME210-I (FFS06720311 and FFS06720311SA) with isolator provides supervision of normally open contacts connected to a single pair of cables. It has selectable status reporting delay making it suitable for monitoring flow switches. There is a DIL switch for address setting. Address range is 1-126.

1.1 Status indications

| Legend | LED Status | Description |
|-----------|-------------------|--------------|
| Poll/ISOL | Flashing Green | Polling LED |
| Poll/ISOL | Continuous Yellow | Isolator LED |
| I/P | Continuous Yellow | Input Fault |
| I/P | Continuous Red | Input Active |

1.2 Dimensions



1.3 Essentia Intelligent Switch Monitor standard resistive monitoring mode connectivity diagram

